

M. Brink, A.J. Jessurun, F. Franchimon, J.E.M.H. van Bronswijk. *An open agent-based home automation system. Gerontechnology 2008;7(2):79* The need to improve dwelling performance with the aid of home automation systems is growing in our aging society. The older cohort requests housing that enhances their vitality and conserves their independence. Suitable systems of sensors, monitors and follow-up services may assist activities of daily living and handle emergencies. Unfortunately most systems currently on the market are expensive, not open, and not as flexible as desired. The solution could be found in software agents¹ that are autonomous and communicate over a computer network² when performing their specific task, such as managing the lighting in the home, or reacting on a fire calamity³. In this study we view the home automation software set-up as an open multi-agent system, and test both its technical feasibility and performance. **Methods** A simple virtual home automation system is designed and built. In order to keep the system both flexible and open, it is allowed to have several agents with the same task. The system can deal with the inevitable task conflicts. Java is taken as the implementation platform and JADE as the framework for the agents of the system. For test purposes a simulation environment is built in Java on a desk-top PC, consisting of a virtual dwelling built of node points. Occupants can move from one point to another based on an agenda that is randomly generated from a set of user activities with a curtain ratio. The following tests have been performed: reliability (error sensibility, error handling, and number of errors), latency (delay times in relation to required speed in actual life), and simplicity (logical structure, ease of adding new agents and of debugging). Subsequently simulation results with and without home automation were compared. **Results and discussion** To increase flexibility, reliability and eventually reducing costs, each component in the designed system has its own agent. Simulations showed robust agents that functioned with little errors. When errors were installed consciously in one agent, other agents continued to perform, but the performance of the system as a whole reduced dramatically. No large delays were found. This could be caused by the fact that communications of agents was simulated locally on the desktop. Logical structure and suitable simplicity allowed for the easy addition of new agents. Dwelling performance remained satisfactory. The system as a whole did not fail. **Conclusion** Technical feasibility and performance of newly designed, open, agent-based home automation system software proved satisfactory. It contained lighting management, access control and both an intelligent intercom system and telephone switch board, but could easily be expanded with other functionalities. Implementing such a system could make feasible the mass introduction of systems to assist activities of daily living and handle emergencies in dwellings for older adults.

References

1. Cook DJ, Youngblood M, Das SK. A multi-agent approach to controlling a smart environment. Berlin: Springer; 2006; pp 165-182
 2. Leventis A, Antonakopoulos T, Stavroulopoulos C, Luckenbach T, Makios V. IEEE Transactions on Consumer Electronics 2003;49:328-336
 3. Haigh KZ, Phelps J, Geib CW. Proceedings of the 1st international joint conference on Autonomous agents and multiagent systems: part 2, session 6A: applications; 2002; pp 578-586
- Keywords:** home automation, domotics, ICT, multi agent system (MAS), JAVA, JADE
Address: Eindhoven University of Technology, the Netherlands; E: m.brink@student.tue.nl